

Water Quality Summary Report

Period:	From	1 st January 2020	To	31 st December 2020
Zone Name:	Kingsfleet, Thetford, Norfolk			
Zone Reference:	ZAAW02			

Parameter name	Units	Samples taken	< or >	Min	Mean	< or >	Max	Regulatory Limit or Range	No of Failures
Colour	mg/l Pt/Co	3	<	2.9	2.9	<	2.9	20	0
Turbidity	NTU	3	<	0.15	0.18		0.24	4	0
Odour	No.	3		0	0		0	1	0
Taste (Taste Quant)	No.	3		0	0		0	1	0
Hydrogen ion (pH) - Indicator (Hydrogen ion) (pH)	pH value	3		7.23	7.45		7.62	6.5(min) to 9.5(max)	0
Sulphate	mg/l SO4	3		16.6	17.2		18.3	250	0
Sodium (Total)	mg/l Na	3		9.8	10.0		10.3	200	0
Nitrate (Total)	mg/l NO3	3		36.4	37.5		39.2	50	0
Nitrite - Consumer's Taps	mg/l NO2	3	<	0.002	0.003	<	0.004	0.5	0
Nitrite/Nitrate formula	mg/l	3		0.73	0.75		0.78	1	0
Ammonium (Total)	mg/l NH4	3	<	0.008	0.009		0.011	0.5	0
Total Organic Carbon	mg/l C	3	<	0.6	0.7		0.9	0	0
Aluminium (Total)	µg/l Al	3	<	6.9	11.9	<	14.5	200	0
Iron (Total)	µg/l Fe	3	<	5.23	5.23	<	5.23	200	0
Manganese (Total)	µg/l Mn	3	<	0.85	0.85	<	0.85	50	0
Copper (Total)	mg/l Cu	3		0.0169	0.1103		0.281	2	0
Fluoride (Total)	mg/l F	3		0.11	0.13		0.14	1.5	0
Arsenic (Total)	µg/l As	3		0.2	0.2		0.21	10	0
Cadmium (Total)	µg/l Cd	3	<	0.01	0.02	<	0.03	5	0
Cyanide (Total)	µg/l CN	3	<	5.5	5.5	<	5.5	50	0

Chromium (Total)	µg/l Cr	3		0.07	0.22		0.41	50	0
Mercury (Total)	µg/l Hg	3	<	0.06	0.06	<	0.06	1	0
Nickel (Total)	µg/l Ni	3		2.75	35.43		100	20	1
Lead (10)	µg/l Pb	3		0.15	0.60		1.39	10	0
Antimony	µg/l Sb	3		0.06	0.08		0.11	5	0
Selenium (Total)	µg/l Se	3		0.68	0.78		0.9	10	0
Pesticides (Total by Calculation)	µg/l	3		0.005	0.006		0.007	0.5	0
Polycyclic Aromatic Hydrocarbons (Total by Calculation)	µg/l	3		0	0		0	0.1	0
Coliform Bacteria (Indicator)	No. /100ml	10		0	0		0	1	0
E.Coli (faecal coliforms Confirmed)	No. /100ml	10		0	0		0	1	0
Enterococci (Confirmed)	No. /100ml	3		0	0		0	1	0
Clostridium Perfringens (Sulphite-reducing Clostridia) (Confirmed)	No. /100ml	3		0	0		0	1	0
Colony Counts After 3 Days At 22øc (Colony Counts)	Count/ml at 22øc	3		0	7		19	0	0
Residual Disinfectant - Total	mg/l	10		0.38	0.53		0.65	0	0
Colony Counts After 48 Hours At 37øc (Colony Counts)	Count/ml at 37øc	3		0	0		0	0	0
Conductivity (Electrical Conductivity)	µS/cm @ 20 °C	3		465	478		490	2500	0
Chloride	mg/l C	3		26.8	27.3		27.8	250	0
Boron	mg/l B	3	<	0.032	0.032	<	0.032	1	0
Benzo[a]Pyrene (Total)	µg/l	3	<	0.0006	0.0006	<	0.0006	0.01	0
Tetrachloromethane (Total)	µg/l	3	<	0.13	0.13	<	0.13	3	0
Trichloroethene & Tetrachloroethene - Sum Of 2 Substances (Total by Calculation)	µg/l	3		0	0		0.75	10	0
Trihalomethanes (Total by Calculation)	µg/l	3		6.2	7.7		8.56	100	0
1,2 Dichloroethane (Total)	µg/l	3	<	0.16	0.16	<	0.16	3	0
Benzene (Total)	µg/l	3	<	0.09	0.09	<	0.09	1	0
Bromate	µg/l BrO3	3	<	0.15	0.15	<	0.15	10	0
Gross Alpha	Bq/l	2	<	0.019	0.019	<	0.019	0.1	0
Gross Beta	Bq/l	2		0.038	0.042		0.046	1.0	0
Tritium	Bq/l	2	<	5.6	5.6	<	5.6	10.0	0

Atrazine (Total)	µg/l	3		0.005	0.006		0.007	0.1	0
Bentazone (Total)	µg/l	3	<	0.004	0.004	<	0.004	0.1	0
Dichlorprop (Total)	µg/l	3	<	0.017	0.017	<	0.017	0.1	0
Simazine (Total)	µg/l	3	<	0.004	0.004	<	0.004	0.1	0

Commentary on Water Quality

All the samples collected from this zone to date have complied with the Water Supply (Water Quality) Regulations 2016. No Undertakings or Authorised Departures currently apply to this water supply zone.

Additional Water Quality Information

The supply to this area is from ground water treated at Two Mile Bottom Water Treatment Works. These works are owned and operated by Anglian Water. Icosa Water take a bulk supply of water from Anglian Water with the connection point occurring in Anglian Water's Two Mile Bottom supply zone. This water is transported via Icosa Waters publicly regulated water supply network to supply the area around Kingsfleet, Thetford.

Water Hardness Information

Hardness Classification	Hard
Calcium Carbonate (CaCO₃)	243 ppm
Calcium	97 ppm
Degrees Clark	17.0
Degrees French	24.3
Degrees German	13.6
Millimoles per litre	2.4