

Water Quality Summary Report

Period:	From	17 th September 2020	To	31 st December 2020
Zone Name:	Headcorn (Includes Forstal Lane, Coxheath)			
Zone Reference	ZASE03			

Parameter name	Units	Samples taken	< or >	Min	Mean	< or >	Max	Regulatory Limit or Range	No of Failures
Colour	mg/l Pt/Co	1	<	2.9	2.9	<	2.9	20	0
Turbidity	NTU	1		0.16	0.16		0.16	4	0
Odour	No.	1		0	0		0	1	0
Taste (Taste Quant)	No.	1		0	0		0	1	0
Hydrogen ion (pH) - Indicator (Hydrogen ion) (pH)	pH value	1		7.34	7.34		7.34	6.5(min) to 9.5(max)	0
Sulphate	mg/l SO4	1		7.19	7.19		7.19	250	0
Sodium (Total)	mg/l Na	1		9.59	9.59		9.59	200	0
Nitrate (Total)	mg/l NO3	1		19.6	19.6		19.6	50	0
Nitrite - Consumer's Taps	mg/l NO2	1	<	0.002	0.002	<	0.002	0.5	0
Nitrite/Nitrate formula	mg/l	1		0.39	0.39		0.39	1	0
Ammonium (Total)	mg/l NH4	1	<	0.008	0.008	<	0.008	0.5	0
Total Organic Carbon	mg/l C	1	<	0.7	0.7	<	0.7	0	0
Aluminium (Total)	µg/l Al	1	<	6.9	6.9	<	6.9	200	0
Iron (Total)	µg/l Fe	1	<	3.72	3.72	<	3.72	200	0
Manganese (Total)	µg/l Mn	1	<	0.3	0.3	<	0.3	50	0
Copper (Total)	mg/l Cu	1		1.883	1.883		1.883	2	0
Fluoride (Total)	mg/l F	1		0.09	0.09		0.09	1.5	0
Arsenic (Total)	µg/l As	1		0.17	0.17		0.17	10	0
Cadmium (Total)	µg/l Cd	1	<	0.03	0.03	<	0.03	5	0
Cyanide (Total)	µg/l CN	1	<	5.5	5.5	<	5.5	50	0

Chromium (Total)	µg/l Cr	1		0.39	0.39		0.39	50	0
Mercury (Total)	µg/l Hg	1	<	0.06	0.06	<	0.06	1	0
Nickel (Total)	µg/l Ni	1		2.01	2.01		2.01	20	0
Lead (10)	µg/l Pb	1		3.83	3.83		3.83	10	0
Antimony	µg/l Sb	1	<	0.07	0.07	<	0.07	5	0
Selenium (Total)	µg/l Se	1		0.6	0.6		0.6	10	0
Pesticides (Total by Calculation)	µg/l	1		0	0		0	0.5	0
Polycyclic Aromatic Hydrocarbons (Total by Calculation)	µg/l	1		0.006	0.006		0.006	0.1	0
Coliform Bacteria (Indicator)	No. /100ml	4		0	0		0	1	0
E.Coli (faecal coliforms Confirmed)	No. /100ml	4		0	0		0	1	0
Enterococci (Confirmed)	No. /100ml	1		0	0		0	1	0
clostridium Perfringens (Sulphite-reducing Clostridia) (Confirmed)	No. /100ml	1		0	0		0	1	0
Colony Counts After 3 Days At 22øc (Colony Counts)	Count/ml at 22øc	1		0	0		0	0	0
Residual Disinfectant - Total	mg/l	4		0.18	0.36		0.57	0	0
Colony Counts After 48 Hours At 37øc (Colony Counts)	Count/ml at 37øc	1		1	1		1	0	0
Conductivity (Electrical Conductivity)	µS/cm @ 20 °C	1		534	534		534	2500	0
Chloride	mg/l C	1		21.8	21.8		21.8	250	0
Boron	mg/l B	1	<	0.032	0.032	<	0.032	1	0
Benzo[a]Pyrene (Total)	µg/l	1		0.0007	0.0007		0.0007	0.01	0
Tetrachloromethane (Total)	µg/l	1	<	0.13	0.13	<	0.13	3	0
Trichloroethene & Tetrachloroethene - Sum Of 2 Substances (Total by Calculation)	µg/l	1		0	0		0	10	0
Trihalomethanes (Total by Calculation)	µg/l	1		3.17	3.17		3.17	100	0
1,2 Dichloroethane (Total)	µg/l	1	<	0.16	0.16	<	0.16	3	0
Benzene (Total)	µg/l	1	<	0.09	0.09	<	0.09	1	0
Bromate	µg/l BrO3	1	<	0.15	0.15	<	0.15	10	0
Gross Alpha	Bq/l	1	<	0.021	0.021	<	0.021	0.1	0
Gross Beta	Bq/l	1		0.024	0.024		0.024	1.0	0
Tritium	Bq/l	1	<	5.6	5.6	<	5.6	10.0	0

Diuron (Total)	µg/l	1	<	0.009	0.009	<	0.009	0.1	0
----------------	------	---	---	-------	-------	---	-------	-----	---

Commentary on Water Quality

All the samples collected from this zone to date have complied with the Water Supply (Water Quality) Regulations 2016. No Undertakings or Authorised Departures currently apply to this water supply zone.

Additional Water Quality Information

The supply to this area is from ground water treated at Wichling Water Treatment Works. These works are owned and operated by South East Water. Icosa Water take a bulk supply of water from South East Water with the connection point occurring in South East Water's Wichling supply zone. This water is transported via Icosa Waters publicly regulated water supply network to supply the area around Ulcombe Road, Headcorn and Forstal Lane, Coxheath.

Water Hardness Information

Hardness Classification	Moderately Hard
Calcium Carbonate (CaCO₃)	154 ppm
Calcium	62 ppm
Degrees Clark	10.8
Degrees French	15.5
Degrees German	8.7
Millimoles per litre	1.6